

GSU Transformer

2804

1 OIL DRY NEW USED REBUILT RENTAL

2 KVA 2500 IMPEDANCE 5.75 % TEMP RISE 65 °

3 1 PHASE 2 PHASE 3 PHASE 3 Ø TO 2 Ø

4 HIGH VOLTAGE BUSHINGS 1 2 3 4 #

LOW VOLTAGE BUSHINGS 1 2 3 4 #

5 MAKE GE Prolec CAT # _____

6 SERIAL # M10L14833 STYLE # _____

7 PRIMARY VOLTAGE 34500gy/19920

8 PRIMARY CONNECTION WYE DELTA (3 Ø ONLY)

9 PRIMARY TAPS 1-A 36225 2-B 35362 3-C 34500

4-D 33637 5-E 32775 6-F _____ 7-G _____

10 SECONDARY VOLTAGE 480

11 SECONDARY CONNECTION WYE DELTA (3 Ø ONLY)

12 TYPE OF FLUID OIL R TEMP FR3 SILICONE

13 GALLONS OF FLUID 490

14 DOES TRANSFORMER HAVE ANY SWITCHING:

14 A OPEN/CLOSE SWITCH YES NO

14 B TAP CHANGER SWITCH YES NO

OUTSIDE TRANS TANK YES NO

14 C DUAL VOLTAGE SWITCH YES NO

OUTSIDE TRANS TANK YES NO

14 D DELTA-WYE SWITCH YES NO

14 E HIGH VOLTAGE FUSED YES NO

TYPE FUSE/MAKE _____ CAT # _____

AMP RATING _____

15 DRY WELL BAYONET CLIP MTD ARC STRANGLER

PRIMARY IS LIVE FRONT DEAD FRONT

IF DEAD FRONT, DO WELLS HAVE LOAD BREAK BUSHINGS IN THEM:

YES NO LIVE CONVERSION ARRESTORS

DEAD BREAK LOAD BREAK

16 DIMENSIONS: 79" H x 83" Wx 101" D WEIGHT 14633