

GSU Transformer

11001

1	OIL	☒	DRY	☐	NEW	☒	USED	☐	REBUILT	☐	RENTAL	☐
2	KVA	2500			IMPEDANCE	5.9		%	TEMP RISE	65 °		
3	1 PHASE	☐	2 PHASE	☐	3 PHASE	☒	3 Ø TO 2 Ø ☐					
4	HIGH VOLTAGE BUSHINGS	1	☐	2	☐	3	☐	4	☒	#	☐	
	LOW VOLTAGE BUSHINGS	1	☐	2	☐	3	☒	4	☐	#	☐	
5	MAKE	Eaton Cooper						CAT #				
6	SERIAL #	1859000130						STYLE #				
7	PRIMARY VOLTAGE	2.4/4.16y/2.4 x 7.2/12.47y/7.2										
8	PRIMARY CONNECTION	WYE	☒	DELTA	☒	(3 Ø ONLY)						
9	PRIMARY TAPS	1-A	7970/13800			2-B	7620/13200			3-C	7430/12870	
		4-D	7200/12470			5-E	6930/12000			6-F		
										7-G		
10	SECONDARY VOLTAGE	480										
11	SECONDARY CONNECTION	WYE	☐	DELTA	☒	(3 Ø ONLY)						
12	TYPE OF FLUID	OIL	☒	R TEMP	☐	FR3	☐	SILICONE	☐			
13	GALLONS OF FLUID	567										
14	DOES TRANSFORMER HAVE ANY SWITCHING:											
14 A	OPEN/CLOSE SWITCH	YES	☒	NO	☐							
14 B	TAP CHANGER SWITCH	YES	☒	NO	☐							
	OUTSIDE TRANS TANK	YES	☒	NO	☐							
14 C	DUAL VOLTAGE SWITCH	YES	☒	NO	☐							
	OUTSIDE TRANS TANK	YES	☒	NO	☐							
14 D	DELTA-WYE SWITCH	YES	☒	NO	☐							
14 E	HIGH VOLTAGE FUSED	YES	☐	NO	☒							
	TYPE FUSE/MAKE							CAT #				
	AMP RATING											
	DRY WELL	☐	BAYONET	☐	CLIP MTD	☐	ARC STRANGLER	☐				
15	PRIMARY IS	LIVE FRONT	☒	DEAD FRONT	☐							
	IF DEAD FRONT, DO WELLS HAVE LOAD BREAK BUSHINGS IN THEM:											
	YES	☐	NO	☐	LIVE CONVERSION	☐	ARRESTORS	☐				
					DEAD BREAK	☐	LOAD BREAK	☐				
16	DIMENSIONS:	75"	H x	79"	W x	107"	D	WEIGHT	14794			
17	COMMENTS:											